

# 40 CFR Part 112--Oil Pollution Prevention

## Table Of Contents

### Subpart A--Applicability, Definitions, And General Requirements For All Facilities And All Types Of Oils

Sec.

[112.1](#) General Applicability.

[112.2](#) Definitions.

[112.3](#) Requirement To Prepare And Implement A Spill Prevention, Control, And Countermeasure Plan.

[112.4](#) Amendment Of Spill Prevention, Control, And Countermeasure Plan By Regional Administrator.

[112.5](#) Amendment Of Spill Prevention, Control, And Countermeasure Plan By Owners Or Operators.

[112.6](#) Qualified Facility Plan Requirements.

[112.7](#) General Requirements For Spill Prevention, Control, And Countermeasure Plans.

### 40 CFR §112.1 General Applicability.

(a)(1) This part establishes procedures, methods, equipment, and other requirements to prevent the discharge of oil from non-transportation-related onshore and offshore facilities into or upon the navigable waters of the United States or adjoining shorelines, or into or upon the waters of the contiguous zone, or in connection with activities under the Outer Continental Shelf Lands Act or the Deepwater Port Act of 1974, or that may affect natural resources belonging to, appertaining to, or under the exclusive management authority of the United States (including resources under the Magnuson Fishery Conservation and Management Act).

(a)(2) As used in this part, words in the singular also include the plural and words in the masculine gender also include the feminine and vice versa, as the case may require.

(b) Except as provided in paragraph (d) of this section, this part applies to any owner or operator of a non-transportation-related onshore or offshore facility engaged in drilling, producing, gathering, storing, processing, refining, transferring, distributing, using, or consuming oil and oil products, which due to its location, could reasonably be expected to discharge oil in quantities that may be harmful, as described in [part 110](#) of this chapter, into or upon the navigable waters of the United States or adjoining shorelines, or into or upon the waters of the contiguous zone, or in connection with activities under the Outer Continental Shelf Lands Act or the Deepwater Port Act of 1974, or that may affect natural resources belonging to, appertaining to, or under the

exclusive management authority of the United States (including resources under the Magnuson Fishery Conservation and Management Act) that has oil in:

**(b)(1)** Any aboveground container;

**(b)(2)** Any completely buried tank as defined in [§112.2](#);

**(b)(3)** Any container that is used for standby storage, for seasonal storage, or for temporary storage, or not otherwise "permanently closed" as defined in [§112.2](#);

**(b)(4)** Any "bunkered tank" or "partially buried tank" as defined in [§112.2](#), or any container in a vault, each of which is considered an aboveground storage container for purposes of this part.

**(c)** As provided in section 313 of the Clean Water Act (CWA), departments, agencies, and instrumentalities of the Federal government are subject to this part to the same extent as any person.

**(d)** Except as provided in paragraph (f) of this section, this part does not apply to:

**(d)(1)** The owner or operator of any facility, equipment, or operation that is not subject to the jurisdiction of the Environmental Protection Agency (EPA) under section 311(j)(1)(C) of the CWA, as follows:

**(d)(1)(i)** Any onshore or offshore facility, that due to its location, could not reasonably be expected to have a discharge as described in paragraph (b) of this section. This determination must be based solely upon consideration of the geographical and location aspects of the facility (such as proximity to navigable waters or adjoining shorelines, land contour, drainage, etc.) and must exclude consideration of manmade features such as dikes, equipment or other structures, which may serve to restrain, hinder, contain, or otherwise prevent a discharge as described in paragraph (b) of this section.

**(d)(1)(ii)** Any equipment, or operation of a vessel or transportation-related onshore or offshore facility which is subject to the authority and control of the U.S. Department of Transportation, as defined in the Memorandum of Understanding between the Secretary of Transportation and the Administrator of EPA, dated November 24, 1971 ([Appendix A](#) of this part).

**(d)(1)(iii)** Any equipment, or operation of a vessel or onshore or offshore facility which is subject to the authority and control of the U.S. Department of Transportation or the U.S. Department of the Interior, as defined in the Memorandum of Understanding between the Secretary of Transportation, the Secretary of the Interior, and the Administrator of EPA, dated November 8, 1993 ([Appendix B](#) of this part).

**(d)(2)** Any facility which, although otherwise subject to the jurisdiction of EPA, meets both of the following requirements:

(d)(2)(i) The completely buried storage capacity of the facility is 42,000 U.S. gallons or less of oil. For purposes of this exemption, the completely buried storage capacity of a facility excludes the capacity of a completely buried tank, as defined in [§112.2](#), and connected underground piping, underground ancillary equipment, and containment systems, that is currently subject to all of the technical requirements of part 280 of this chapter or all of the technical requirements of a State program approved under part 281 of this chapter, or the capacity of any underground oil storage tanks deferred under 40 CFR part 280 that supply emergency diesel generators at a nuclear power generation facility licensed by the Nuclear Regulatory Commission and subject to any Nuclear Regulatory Commission provision regarding design and quality criteria, including, but not limited to, 10 CFR part 50. The completely buried storage capacity of a facility also excludes the capacity of a container that is "permanently closed," as defined in [§112.2](#) and the capacity of intra-facility gathering lines subject to the regulatory requirements of 49 CFR part 192 or 195.

(d)(2)(ii) The aggregate aboveground storage capacity of the facility is 1,320 U.S. gallons or less of oil. For the purposes of this exemption, only containers with a capacity of 55 U.S. gallons or greater are counted. The aggregate aboveground storage capacity of a facility excludes:

(d)(2)(ii)(A) The capacity of a container that is "permanently closed" as defined in [§112.2](#);

(d)(2)(ii)(B) The capacity of a "motive power container" as defined in [§112.2](#);

(d)(2)(ii)(C) The capacity of hot-mix asphalt or any hot-mix asphalt container;

(d)(2)(ii)(D) The capacity of a container for heating oil used solely at a single-family residence;

(d)(2)(ii)(E) The capacity of pesticide application equipment and related mix containers.

(d)(2)(ii)(F) The capacity of any milk and milk product container and associated piping and appurtenances.

(d)(3) Any offshore oil drilling, production, or workover facility that is subject to the notices and regulations of the Minerals Management Service, as specified in the Memorandum of Understanding between the Secretary of Transportation, the Secretary of the Interior, and the Administrator of EPA, dated November 8, 1993 ([Appendix B](#) of this part).

## **40 CFR §112.2 Definitions.**

For the purposes of this part:

*Adverse weather* means weather conditions that make it difficult for response equipment and personnel to clean up or remove spilled oil, and that must be considered when identifying response systems and equipment in a response plan for the applicable operating environment. Factors to consider include significant wave height as specified in [Appendix E](#) to this part (as appropriate), ice conditions, temperatures, weather-related visibility, and currents within the area in which the systems or equipment is intended to function.

*Alteration* means any work on a container involving cutting, burning, welding, or heating operations that changes the physical dimensions or configuration of the container.

*Animal fat* means a non-petroleum oil, fat, or grease of animal, fish, or marine mammal origin.

*Breakout tank* means a container used to relieve surges in an oil pipeline system or to receive and store oil transported by a pipeline for reinjection and continued transportation by pipeline.

*Bulk storage container* means any container used to store oil. These containers are used for purposes including, but not limited to, the storage of oil prior to use, while being used, or prior to further distribution in commerce. Oil-filled electrical, operating, or manufacturing equipment is not a bulk storage container.

*Bunkered tank* means a container constructed or placed in the ground by cutting the earth and re-covering the container in a manner that breaks the surrounding natural grade, or that lies above grade, and is covered with earth, sand, gravel, asphalt, or other material. A bunkered tank is considered an aboveground storage container for purposes of this part.

*Completely buried tank* means any container completely below grade and covered with earth, sand, gravel, asphalt, or other material. Containers in vaults, bunkered tanks, or partially buried tanks are considered aboveground storage containers for purposes of this part.

*Complex* means a facility possessing a combination of transportation-related and non-transportation-related components that is subject to the jurisdiction of more than one Federal agency under section 311(j) of the CWA.

*Contiguous zone* means the zone established by the United States under Article 24 of the Convention of the Territorial Sea and Contiguous Zone, that is contiguous to the territorial sea and that extends nine miles seaward from the outer limit of the territorial area.

*Contract or other approved means* means:

- (1) A written contractual agreement with an oil spill removal organization that identifies and ensures the availability of the necessary personnel and equipment within appropriate response times; and/or
- (2) A written certification by the owner or operator that the necessary personnel and equipment resources, owned or operated by the facility owner or operator, are available to respond to a discharge within appropriate response times; and/or
- (3) Active membership in a local or regional oil spill removal organization that has identified and ensures adequate access through such membership to necessary personnel and equipment to respond to a discharge within appropriate response times in the specified geographic area; and/or
- (4) Any other specific arrangement approved by the Regional Administrator upon request of the owner or operator.

*Discharge* includes, but is not limited to, any spilling, leaking, pumping, pouring, emitting, emptying, or dumping of oil, but excludes discharges in compliance with a permit under section 402 of the CWA; discharges resulting from circumstances identified, reviewed, and made a part of the public record with respect to a permit issued or modified under section 402 of the CWA, and subject to a condition in such permit; or continuous or anticipated intermittent discharges from a point source, identified in a permit or permit application under section 402 of the CWA, that are caused by events occurring within the scope of relevant operating or treatment systems. For purposes of this part, the term discharge shall not include any discharge of oil that is authorized by a permit issued under section 13 of the River and Harbor Act of 1899 (33 U.S.C. 407).

*Facility* means any mobile or fixed, onshore or offshore building, property, parcel, lease, structure, installation, equipment, pipe, or pipeline (other than a vessel or a public vessel) used in oil well drilling operations, oil production, oil refining, oil storage, oil gathering, oil processing, oil transfer, oil distribution, and oil waste treatment, or in which oil is used, as described in Appendix A to this part. The boundaries of a facility depend on several site-specific factors, including but not limited to, the ownership or operation of buildings, structures, and equipment on the same site and types of activity at the site. Contiguous or non-contiguous buildings, properties, parcels, leases, structures, installations, pipes, or pipelines under the ownership or operation of the same person may be considered separate facilities. Only this definition governs whether a facility is subject to this part.

*Farm* means a facility on a tract of land devoted to the production of crops or raising of animals, including fish, which produced and sold, or normally would have produced and sold, \$1,000 or more of agricultural products during a year.

*Fish and wildlife and sensitive environments* means areas that may be identified by their legal designation or by evaluations of Area Committees (for planning) or members of the Federal On-Scene Coordinator's spill response structure (during responses). These areas may include wetlands, National and State parks, critical habitats for endangered or threatened species, wilderness and natural resource areas, marine sanctuaries and estuarine reserves, conservation areas, preserves, wildlife areas, wildlife refuges, wild and scenic rivers, recreational areas, national forests, Federal and State lands that are research national areas, heritage program areas, land trust areas, and historical and archaeological sites and parks. These areas may also include unique habitats such as aquaculture sites and agricultural surface water intakes, bird nesting areas, critical biological resource areas, designated migratory routes, and designated seasonal habitats.

*Injury* means a measurable adverse change, either long- or short-term, in the chemical or physical quality or the viability of a natural resource resulting either directly or indirectly from exposure to a discharge, or exposure to a product of reactions resulting from a discharge.

*Loading/unloading rack* means a fixed structure (such as a platform, gangway) necessary for loading or unloading a tank truck or tank car, which is located at a facility subject to the requirements of this part. A loading/unloading rack includes a loading or unloading arm, and

may include any combination of the following: piping assemblages, valves, pumps, shut-off devices, overfill sensors, or personnel safety devices.

*Maximum extent practicable* means within the limitations used to determine oil spill planning resources and response times for on-water recovery, shoreline protection, and cleanup for worst case discharges from onshore non-transportation-related facilities in adverse weather. It includes the planned capability to respond to a worst case discharge in adverse weather, as contained in a response plan that meets the requirements in [§112.20](#) or in a specific plan approved by the Regional Administrator.

*Mobile refueler* means a bulk storage container onboard a vehicle or towed, that is designed or used solely to store and transport fuel for transfer into or from an aircraft, motor vehicle, locomotive, vessel, ground service equipment, or other oil storage container.

*Motive power container* means any onboard bulk storage container used primarily to power the movement of a motor vehicle, or ancillary onboard oil-filled operational equipment. An onboard bulk storage container which is used to store or transfer oil for further distribution is not a motive power container. The definition of motive power container does not include oil drilling or workover equipment, including rigs.

*Navigable waters* of the United States means "navigable waters" as defined in section 502(7) of the FWPCA, and includes:

- (1) All navigable waters of the United States, as defined in judicial decisions prior to passage of the 1972 Amendments to the FWPCA (Pub. L. 92-500), and tributaries of such waters;
- (2) Interstate waters;
- (3) Intrastate lakes, rivers, and streams which are utilized by interstate travelers for recreational or other purposes; and
- (4) Intrastate lakes, rivers, and streams from which fish or shellfish are taken and sold in interstate commerce.

*Non-petroleum oil* means oil of any kind that is not petroleum-based, including but not limited to: Fats, oils, and greases of animal, fish, or marine mammal origin; and vegetable oils, including oils from seeds, nuts, fruits, and kernels.

*Offshore facility* means any facility of any kind (other than a vessel or public vessel) located in, on, or under any of the navigable waters of the United States, and any facility of any kind that is subject to the jurisdiction of the United States and is located in, on, or under any other waters.

*Oil* means oil of any kind or in any form, including, but not limited to: fats, oils, or greases of animal, fish, or marine mammal origin; vegetable oils, including oils from seeds, nuts, fruits, or kernels; and, other oils and greases, including petroleum, fuel oil, sludge, synthetic oils, mineral oils, oil refuse, or oil mixed with wastes other than dredged spoil.

*Oil-filled operational equipment* means equipment that includes an oil storage container (or multiple containers) in which the oil is present solely to support the function of the apparatus or the device. Oil-filled operational equipment is not considered a bulk storage container, and does not include oil-filled manufacturing equipment (flow-through process). Examples of oil-filled operational equipment include, but are not limited to, hydraulic systems, lubricating systems (e.g., those for pumps, compressors and other rotating equipment, including pumpjack lubrication systems), gear boxes, machining coolant systems, heat transfer systems, transformers, circuit breakers, electrical switches, and other systems containing oil solely to enable the operation of the device.

*Oil Spill Removal Organization* means an entity that provides oil spill response resources, and includes any for-profit or not-for-profit contractor, cooperative, or in-house response resources that have been established in a geographic area to provide required response resources.

*Onshore facility* means any facility of any kind located in, on, or under any land within the United States, other than submerged lands.

*Owner or operator* means any person owning or operating an onshore facility or an offshore facility, and in the case of any abandoned offshore facility, the person who owned or operated or maintained the facility immediately prior to such abandonment.

*Partially buried tank* means a storage container that is partially inserted or constructed in the ground, but not entirely below grade, and not completely covered with earth, sand, gravel, asphalt, or other material. A partially buried tank is considered an aboveground storage container for purposes of this part.

*Permanently closed* means any container or facility for which:

- (1) All liquid and sludge has been removed from each container and connecting line; and
- (2) All connecting lines and piping have been disconnected from the container and blanked off, all valves (except for ventilation valves) have been closed and locked, and conspicuous signs have been posted on each container stating that it is a permanently closed container and noting the date of closure.

*Person* includes an individual, firm, corporation, association, or partnership.

*Petroleum oil* means petroleum in any form, including but not limited to crude oil, fuel oil, mineral oil, sludge, oil refuse, and refined products.

*Produced water container* means a storage container at an oil production facility used to store the produced water after initial oil/water separation, and prior to reinjection, beneficial reuse, discharge, or transfer for disposal.

*Production facility* means all structures (including but not limited to wells, platforms, or storage facilities), piping (including but not limited to flowlines or intra-facility gathering lines), or

equipment (including but not limited to workover equipment, separation equipment, or auxiliary non-transportation-related equipment) used in the production, extraction, recovery, lifting, stabilization, separation or treating of oil (including condensate), or associated storage or measurement, and is located in an oil or gas field, at a facility. This definition governs whether such structures, piping, or equipment are subject to a specific section of this part.

*Regional Administrator* means the Regional Administrator of the Environmental Protection Agency, in and for the Region in which the facility is located.

*Repair* means any work necessary to maintain or restore a container to a condition suitable for safe operation, other than that necessary for ordinary, day-to-day maintenance to maintain the functional integrity of the container and that does not weaken the container.

*Spill Prevention, Control, and Countermeasure Plan; SPCC Plan, or Plan* means the document required by [§112.3](#) that details the equipment, workforce, procedures, and steps to prevent, control, and provide adequate countermeasures to a discharge.

*Storage capacity* of a container means the shell capacity of the container.

*Transportation-related and non-transportation-related*, as applied to an onshore or offshore facility, are defined in the Memorandum of Understanding between the Secretary of Transportation and the Administrator of the Environmental Protection Agency, dated November 24, 1971, ([Appendix A](#) of this part).

*United States* means the States, the District of Columbia, the Commonwealth of Puerto Rico, the Commonwealth of the Northern Mariana Islands, Guam, American Samoa, the U.S. Virgin Islands, and the Pacific Island Governments.

*Vegetable oil* means a non-petroleum oil or fat of vegetable origin, including but not limited to oils and fats derived from plant seeds, nuts, fruits, and kernels.

*Vessel* means every description of watercraft or other artificial contrivance used, or capable of being used, as a means of transportation on water, other than a public vessel.

*Wetlands* means those areas that are inundated or saturated by surface or groundwater at a frequency or duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include playa lakes, swamps, marshes, bogs, and similar areas such as sloughs, prairie potholes, wet meadows, prairie river overflows, mudflats, and natural ponds.

*Worst case discharge* for an onshore non-transportation-related facility means the largest foreseeable discharge in adverse weather conditions as determined using the worksheets in [Appendix D](#) to this part.

## **40 CFR §112.3 Requirement To Prepare And Implement A Spill Prevention, Control, And Countermeasure Plan.**



The owner or operator of an onshore or offshore facility subject to this section must prepare in writing and implement a Spill Prevention Control and Countermeasure Plan (hereafter "SPCC Plan" or "Plan"), in accordance with [§112.7](#) and any other applicable section of this part.

(a)(1) Except as otherwise provided in this section, if your facility, or mobile or portable facility, was in operation on or before August 16, 2002, you must maintain your Plan, but must amend it, if necessary to ensure compliance with this part, and implement the amended Plan no later than November 10, 2011. If such a facility becomes operational after August 16, 2002, through November 10, 2011, and could reasonably be expected to have a discharge as described in [§112.1\(b\)](#), you must prepare and implement a Plan on or before November 10, 2011. If such a facility (excluding oil production facilities) becomes operational after November 10, 2011, and could reasonably be expected to have a discharge as described in [§112.1\(b\)](#), you must prepare and implement a Plan before you begin operations. You are not required to prepare a new Plan each time you move a mobile or portable facility to a new site; the Plan may be general. When you move the mobile or portable facility, you must locate and install it using the discharge prevention practices outlined in the Plan for the facility. The Plan is applicable only while the mobile or portable facility is in a fixed (non-transportation) operating mode.

(a)(2) If your drilling, production or workover facility, including a mobile or portable facility, is offshore or has an offshore component; or your onshore facility is required to have and submit a Facility Response Plan pursuant to 40 CFR 112.20(a), and was in operation on or before August 16, 2002, you must maintain your Plan, but must amend it, if necessary to ensure compliance with this part, and implement the amended Plan no later than November 10, 2010. If such a facility becomes operational after August 16, 2002, through November 10, 2010, and could reasonably be expected to have a discharge as described in [§112.1\(b\)](#), you must prepare and implement a Plan on or before November 10, 2010. If such a facility (excluding oil production facilities) becomes operational after November 10, 2010, and could reasonably be expected to have a discharge as described in [§112.1\(b\)](#), you must prepare and implement a Plan before you begin operations. You are not required to prepare a new Plan each time you move a mobile or portable facility to a new site; the Plan may be general. When you move the mobile or portable facility, you must locate and install it using the discharge prevention practices outlined in the Plan for the facility. The Plan is applicable only while the mobile or portable facility is in a fixed (non-transportation) operating mode.

(a)(3) If your farm, as defined in [§112.2](#), was in operation on or before August 16, 2002, you must maintain your Plan, but must amend it, if necessary to ensure compliance with this part, and implement the amended Plan on or before May 10, 2013. If your farm becomes operational after August 16, 2002, through May 10, 2013, and could reasonably be expected to have a discharge as described in [§112.1\(b\)](#), you must prepare and implement a Plan on or before May 10, 2013. If your farm becomes operational after May 10, 2013, and could reasonably be expected to have a discharge as described in [§112.1\(b\)](#), you must prepare and implement a Plan before you begin operations.

(b) If your oil production facility as described in paragraph (a)(1) of this section becomes operational after November 10, 2011, or as described in paragraph (a)(2) of this section becomes operational after November 10, 2010, and could reasonably be expected to have a discharge as

described in [§112.1\(b\)](#), you must prepare and implement a Plan within six months after you begin operations.

(c) [Reserved]

(d) Except as provided in [§112.6](#), a licensed Professional Engineer must review and certify a Plan for it to be effective to satisfy the requirements of this part.

(d)(1) By means of this certification the Professional Engineer attests:

(d)(1)(i) That he is familiar with the requirements of this part;

(d)(1)(ii) That he or his agent has visited and examined the facility;

(d)(1)(iii) That the Plan has been prepared in accordance with good engineering practice, including consideration of applicable industry standards, and with the requirements of this part;

(d)(1)(iv) That procedures for required inspections and testing have been established; and

(d)(1)(v) That the Plan is adequate for the facility.

(d)(1)(vi) That, if applicable, for a produced water container subject to [§112.9\(c\)\(6\)](#), any procedure to minimize the amount of free-phase oil is designed to reduce the accumulation of free-phase oil and the procedures and frequency for required inspections, maintenance and testing have been established and are described in the Plan.

(d)(2) Such certification shall in no way relieve the owner or operator of a facility of his duty to prepare and fully implement such Plan in accordance with the requirements of this part.

(e) If you are the owner or operator of a facility for which a Plan is required under this section, you must:

(e)(1) Maintain a complete copy of the Plan at the facility if the facility is normally attended at least four hours per day, or at the nearest field office if the facility is not so attended, and

(e)(2) Have the Plan available to the Regional Administrator for on-site review during normal working hours.

(f) *Extension of time.* (1) The Regional Administrator may authorize an extension of time for the preparation and full implementation of a Plan, or any amendment thereto, beyond the time permitted for the preparation, implementation, or amendment of a Plan under this part, when he finds that the owner or operator of a facility subject to this section, cannot fully comply with the requirements as a result of either nonavailability of qualified personnel, or delays in construction or equipment delivery beyond the control and without the fault of such owner or operator or his agents or employees.

(f)(2) If you are an owner or operator seeking an extension of time under paragraph (f)(1) of this section, you may submit a written extension request to the Regional Administrator. Your request must include:

(f)(2)(i) A full explanation of the cause for any such delay and the specific aspects of the Plan affected by the delay;

(f)(2)(ii) A full discussion of actions being taken or contemplated to minimize or mitigate such delay; and

(f)(2)(iii) A proposed time schedule for the implementation of any corrective actions being taken or contemplated, including interim dates for completion of tests or studies, installation and operation of any necessary equipment, or other preventive measures. In addition you may present additional oral or written statements in support of your extension request.

(f)(3) The submission of a written extension request under paragraph (f)(2) of this section does not relieve you of your obligation to comply with the requirements of this part. The Regional Administrator may request a copy of your Plan to evaluate the extension request. When the Regional Administrator authorizes an extension of time for particular equipment or other specific aspects of the Plan, such extension does not affect your obligation to comply with the requirements related to other equipment or other specific aspects of the Plan for which the Regional Administrator has not expressly authorized an extension.

(g) *Qualified Facilities.* The owner or operator of a qualified facility as defined in this subparagraph may self-certify his facility's Plan, as provided in [§112.6](#). A qualified facility is one that meets the following Tier I or Tier II qualified facility criteria:

(g)(1) A Tier I qualified facility meets the qualification criteria in paragraph (g)(2) of this section and has no individual aboveground oil storage container with a capacity greater than 5,000 U.S. gallons.

(g)(2) A Tier II qualified facility is one that has had no single discharge as described in [§112.1\(b\)](#) exceeding 1,000 U.S. gallons or no two discharges as described in [§112.1\(b\)](#) each exceeding 42 U.S. gallons within any twelve month period in the three years prior to the SPCC Plan self-certification date, or since becoming subject to this part if the facility has been in operation for less than three years (other than discharges as described in [§112.1\(b\)](#) that are the result of natural disasters, acts of war, or terrorism), and has an aggregate aboveground oil storage capacity of 10,000 U.S. gallons or less.

#### **40 CFR §112.5 Amendment Of Spill Prevention, Control, And Countermeasure Plan By Owners Or Operators.**

If you are the owner or operator of a facility subject to this part, you must:

(a) Amend the SPCC Plan for your facility in accordance with the general requirements in [§112.7](#), and with any specific section of this part applicable to your facility, when there is a

change in the facility design, construction, operation, or maintenance that materially affects its potential for a discharge as described in [§112.1\(b\)](#). Examples of changes that may require amendment of the Plan include, but are not limited to: commissioning or decommissioning containers; replacement, reconstruction, or movement of containers; reconstruction, replacement, or installation of piping systems; construction or demolition that might alter secondary containment structures; changes of product or service; or revision of standard operation or maintenance procedures at a facility. An amendment made under this section must be prepared within six months, and implemented as soon as possible, but not later than six months following preparation of the amendment.

(b) Notwithstanding compliance with paragraph (a) of this section, complete a review and evaluation of the SPCC Plan at least once every five years from the date your facility becomes subject to this part; or, if your facility was in operation on or before August 16, 2002, five years from the date your last review was required under this part. As a result of this review and evaluation, you must amend your SPCC Plan within six months of the review to include more effective prevention and control technology if the technology has been field- proven at the time of the review and will significantly reduce the likelihood of a discharge as described in [§112.1\(b\)](#) from the facility. You must implement any amendment as soon as possible, but not later than six months following preparation of any amendment. You must document your completion of the review and evaluation, and must sign a statement as to whether you will amend the Plan, either at the beginning or end of the Plan or in a log or an appendix to the Plan. The following words will suffice, "I have completed review and evaluation of the SPCC Plan for (name of facility) on (date), and will (will not) amend the Plan as a result."

(c) Except as provided in [§112.6](#), have a Professional Engineer certify any technical amendments to your Plan in accordance with [§112.3\(d\)](#).

#### **40 CFR §112.6 Qualified Facility Plan Requirements.**

Qualified facilities meeting the Tier I applicability criteria in [§112.3\(g\)\(1\)](#) are subject to the requirements in paragraph (a) of this section. Qualified facilities meeting the Tier II applicability criteria in [§112.3\(g\)\(2\)](#) are subject to the requirements in paragraph (b) of this section.

##### ***(a) Tier I Qualified Facilities.***

**(a)(1) Preparation and Self-Certification of the Plan.** If you are an owner or operator of a facility that meets the Tier I qualified facility criteria in [§112.3\(g\)\(1\)](#), you must either: comply with the requirements of paragraph (a)(3) of this section; or prepare and implement a Plan meeting requirements of paragraph (b) of this section; or prepare and implement a Plan meeting the general Plan requirements in [§112.7](#) and applicable requirements in subparts B and C, including having the Plan certified by a Professional Engineer as required under [§112.3\(d\)](#). If you do not follow the [Appendix G](#) template, you must prepare an equivalent Plan that meets all of the applicable requirements listed in this part, and you must supplement it with a section cross-referencing the location of requirements listed in this part and the equivalent requirements in the other prevention plan. To complete the template in [Appendix G](#), you must certify that:

(a)(1)(i) You are familiar with the applicable requirements of [40 CFR part 112](#);

(a)(1)(ii) You have visited and examined the facility;

(a)(1)(iii) You prepared the Plan in accordance with accepted and sound industry practices and standards;

(a)(1)(iv) You have established procedures for required inspections and testing in accordance with industry inspection and testing standards or recommended practices;

(a)(1)(v) You will fully implement the Plan;

(a)(1)(vi) The facility meets the qualification criteria in [§112.3\(g\)\(1\)](#);

(a)(1)(vii) The Plan does not deviate from any requirement of this part as allowed by [§112.7\(a\)\(2\)](#) and [112.7\(d\)](#) or include measures pursuant to [§112.9\(c\)\(6\)](#) for produced water containers and any associated piping; and

(a)(1)(viii) The Plan and individual(s) responsible for implementing this Plan have the approval of management, and the facility owner or operator has committed the necessary resources to fully implement this Plan.

(a)(2) *Technical Amendments.* You must certify any technical amendments to your Plan in accordance with paragraph (a)(1) of this section when there is a change in the facility design, construction, operation, or maintenance that affects its potential for a discharge as described in [§112.1\(b\)](#). If the facility change results in the facility no longer meeting the Tier I qualifying criteria in [§112.3\(g\)\(1\)](#) because an individual oil storage container capacity exceeds 5,000 U.S. gallons or the facility capacity exceeds 10,000 U.S. gallons in aggregate aboveground storage capacity, within six months following preparation of the amendment, you must either:

(a)(2)(i) Prepare and implement a Plan in accordance with [§112.6\(b\)](#) if you meet the Tier II qualified facility criteria in [§112.3\(g\)\(2\)](#); or

(a)(2)(ii) Prepare and implement a Plan in accordance with the general Plan requirements in [§112.7](#), and applicable requirements in subparts B and C, including having the Plan certified by a Professional Engineer as required under [§112.3\(d\)](#).

(a)(3) *Plan Template and Applicable Requirements.* Prepare and implement an SPCC Plan that meets the following requirements under [§112.7](#) and in subparts B and C of this part: introductory paragraph of [§§112.7](#), [112.7\(a\)\(3\)\(i\)](#), [112.7\(a\)\(3\)\(iv\)](#), [112.7\(a\)\(3\)\(vi\)](#), [112.7\(a\)\(4\)](#), [112.7\(a\)\(5\)](#), [112.7\(c\)](#), [112.7\(e\)](#), [112.7\(f\)](#), [112.7\(g\)](#), [112.7\(k\)](#), [112.8\(b\)\(1\)](#), [112.8\(b\)\(2\)](#), [112.8\(c\)\(1\)](#), [112.8\(c\)\(3\)](#), [112.8\(c\)\(4\)](#), [112.8\(c\)\(5\)](#), [112.8\(c\)\(6\)](#), [112.8\(c\)\(10\)](#), [112.8\(d\)\(4\)](#), [112.9\(b\)](#), [112.9\(c\)\(1\)](#), [112.9\(c\)\(2\)](#), [112.9\(c\)\(3\)](#), [112.9\(c\)\(4\)](#), [112.9\(c\)\(5\)](#), [112.9\(d\)\(1\)](#), [112.9\(d\)\(3\)](#), [112.9\(d\)\(4\)](#), [112.10\(b\)](#), [112.10\(c\)](#), [112.10\(d\)](#), [112.12\(b\)\(1\)](#), [112.12\(b\)\(2\)](#), [112.12\(c\)\(1\)](#), [112.12\(c\)\(3\)](#), [112.12\(c\)\(4\)](#), [112.12\(c\)\(5\)](#), [112.12\(c\)\(6\)](#), [112.12\(c\)\(10\)](#), and [112.12\(d\)\(4\)](#). The template in [Appendix G](#) to this part has been developed to meet the requirements of [40 CFR part](#)

[112](#) and, when completed and signed by the owner or operator, may be used as the SPCC Plan. Additionally, you must meet the following requirements:

**(a)(3)(i)** *Failure analysis, in lieu of the requirements in [§112.7\(b\)](#).* Where experience indicates a reasonable potential for equipment failure (such as loading or unloading equipment, tank overflow, rupture, or leakage, or any other equipment known to be a source of discharge), include in your Plan a prediction of the direction and total quantity of oil which could be discharged from the facility as a result of each type of major equipment failure.

**(a)(3)(ii)** *Bulk storage container secondary containment, in lieu of the requirements in [§§112.8\(c\)\(2\)](#) and [\(c\)\(11\)](#) and [112.12\(c\)\(2\)](#) and [\(c\)\(11\)](#).* Construct all bulk storage container installations (except mobile refuelers and other non-transportation-related tank trucks), including mobile or portable oil storage containers, so that you provide a secondary means of containment for the entire capacity of the largest single container plus additional capacity to contain precipitation. Dikes, containment curbs, and pits are commonly employed for this purpose. You may also use an alternative system consisting of a drainage trench enclosure that must be arranged so that any discharge will terminate and be safely confined in a catchment basin or holding pond. Position or locate mobile or portable oil storage containers to prevent a discharge as described in [§112.1\(b\)](#).

**(a)(3)(iii)** *Overfill prevention, in lieu of the requirements in [§§112.8\(c\)\(8\)](#) and [112.12\(c\)\(8\)](#).* Ensure that each container is provided with a system or documented procedure to prevent overfills of the container, describe the system or procedure in the SPCC Plan and regularly test to ensure proper operation or efficacy.

**(b)** *Tier II Qualified Facilities.*

**(b)(1)** *Preparation and Self-Certification of Plan.* If you are the owner or operator of a facility that meets the Tier II qualified facility criteria in [§112.3\(g\)\(2\)](#), you may choose to self-certify your Plan. You must certify in the Plan that:

**(b)(1)(i)** You are familiar with the requirements of this part;

**(b)(1)(ii)** You have visited and examined the facility;

**(b)(1)(iii)** The Plan has been prepared in accordance with accepted and sound industry practices and standards, and with the requirements of this part;

**(b)(1)(iv)** Procedures for required inspections and testing have been established;

**(b)(1)(v)** You will fully implement the Plan;

**(b)(1)(vi)** The facility meets the qualification criteria set forth under [§112.3\(g\)\(2\)](#);



**(b)(1)(vii)** The Plan does not deviate from any requirement of this part as allowed by [§112.7\(a\)\(2\)](#) and [112.7\(d\)](#) or include measures pursuant to [§112.9\(c\)\(6\)](#) for produced water containers and any associated piping, except as provided in paragraph (b)(3) of this section; and

**(b)(1)(viii)** The Plan and individual(s) responsible for implementing the Plan have the full approval of management and the facility owner or operator has committed the necessary resources to fully implement the Plan.

**(b)(2) *Technical Amendments.*** If you self-certify your Plan pursuant to paragraph (b)(1) of this section, you must certify any technical amendments to your Plan in accordance with paragraph (b)(1) of this section when there is a change in the facility design, construction, operation, or maintenance that affects its potential for a discharge as described in [§112.1\(b\)](#), except:

**(b)(2)(i)** If a Professional Engineer certified a portion of your Plan in accordance with paragraph (b)(4) of this section, and the technical amendment affects this portion of the Plan, you must have the amended provisions of your Plan certified by a Professional Engineer in accordance with paragraph (b)(4)(ii) of this section.

**(b)(2)(ii)** If the change is such that the facility no longer meets the Tier II qualifying criteria in [§112.3\(g\)\(2\)](#) because it exceeds 10,000 U.S. gallons in aggregate aboveground storage capacity you must, within six months following the change, prepare and implement a Plan in accordance with the general Plan requirements in [§112.7](#) and the applicable requirements in subparts B and C of this part, including having the Plan certified by a Professional Engineer as required under [§112.3\(d\)](#).

**(b)(3) *Applicable Requirements.*** Except as provided in this paragraph, your self-certified SPCC Plan must comply with [§112.7](#) and the applicable requirements in subparts B and C of this part:

**(b)(3)(i) *Environmental Equivalence.*** Your Plan may not include alternate methods which provide environmental equivalence pursuant to [§112.7\(a\)\(2\)](#), unless each alternate method has been reviewed and certified in writing by a Professional Engineer, as provided in paragraph (b)(4) of this section.

**(b)(3)(ii) *Impracticability.*** Your Plan may not include any determinations that secondary containment is impracticable and provisions in lieu of secondary containment pursuant to [§112.7\(d\)](#), unless each such determination and alternate measure has been reviewed and certified in writing by a Professional Engineer, as provided in paragraph (b)(4) of this section.

**(b)(3)(iii) *Produced Water Containers.*** Your Plan may not include any alternative procedures for skimming produced water containers in lieu of sized secondary containment pursuant to [§112.9\(c\)\(6\)](#), unless they have been reviewed and certified in writing by a Professional Engineer, as provided in paragraph (b)(4) of this section.

**(b)(4) *Professional Engineer Certification of Portions of a Qualified Facility's Self-Certified Plan.***

(b)(4)(i) As described in paragraph (b)(3) of this section, the facility owner or operator may not self-certify alternative measures allowed under [§112.7\(a\)\(2\)](#) or [\(d\)](#), that are included in the facility's Plan. Such measures must be reviewed and certified, in writing, by a licensed Professional Engineer. For each alternative measure allowed under [§112.7\(a\)\(2\)](#), the Plan must be accompanied by a written statement by a Professional Engineer that states the reason for nonconformance and describes the alternative method and how it provides equivalent environmental protection in accordance with [§112.7\(a\)\(2\)](#). For each determination of impracticability of secondary containment pursuant to [§112.7\(d\)](#), the Plan must clearly explain why secondary containment measures are not practicable at this facility and provide the alternative measures required in [§112.7\(d\)](#) in lieu of secondary containment. By certifying each measure allowed under [§112.7\(a\)\(2\)](#) and [\(d\)](#), the Professional Engineer attests:

(b)(4)(i)(A) That he is familiar with the requirements of this part;

(b)(4)(i)(B) That he or his agent has visited and examined the facility; and

(b)(4)(i)(C) That the alternative method of environmental equivalence in accordance with [§112.7\(a\)\(2\)](#) or the determination of impracticability and alternative measures in accordance with [§112.7\(d\)](#) is consistent with good engineering practice, including consideration of applicable industry standards, and with the requirements of this part.

(b)(4)(ii) As described in paragraph (b)(3) of this section, the facility owner or operator may not self-certify measures as described in [§112.9\(c\)\(6\)](#) for produced water containers and any associated piping. Such measures must be reviewed and certified, in writing, by a licensed Professional Engineer, in accordance with [§112.3\(d\)\(1\)\(vi\)](#).

(b)(4)(iii) The review and certification by the Professional Engineer under this paragraph is limited to the alternative method which achieves equivalent environmental protection pursuant to [§112.7\(a\)\(2\)](#); to the impracticability determination and measures in lieu of secondary containment pursuant to [§112.7\(d\)](#); or the measures pursuant to [§112.9\(c\)\(6\)](#) for produced water containers and any associated piping and appurtenances downstream from the container.

#### **40 CFR §112.7 General Requirements For Spill Prevention, Control, And Countermeasure Plans.**

If you are the owner or operator of a facility subject to this part you must prepare a Plan in accordance with good engineering practices. The Plan must have the full approval of management at a level of authority to commit the necessary resources to fully implement the Plan. You must prepare the Plan in writing. If you do not follow the sequence specified in this section for the Plan, you must prepare an equivalent Plan acceptable to the Regional Administrator that meets all of the applicable requirements listed in this part, and you must supplement it with a section cross-referencing the location of requirements listed in this part and the equivalent requirements in the other prevention plan. If the Plan calls for additional facilities or procedures, methods, or equipment not yet fully operational, you must discuss these items in separate paragraphs, and must explain separately the details of installation and operational start-up. As detailed elsewhere in this section, you must also:



(a)(1) Include a discussion of your facility's conformance with the requirements listed in this part.

(a)(2) Comply with all applicable requirements listed in this part. Except as provided in [§112.6](#), your Plan may deviate from the requirements in paragraphs (g), (h)(2) and (3), and (i) of this section and the requirements in subparts B and C of this part, except the secondary containment requirements in paragraphs (c) and (h)(1) of this section, and [§§112.8\(c\)\(2\)](#), [112.8\(c\)\(11\)](#), [112.9\(c\)\(2\)](#), [112.9\(d\)\(3\)](#), [112.10\(c\)](#), [112.12\(c\)\(2\)](#), and [112.12\(c\)\(11\)](#), where applicable to a specific facility, if you provide equivalent environmental protection by some other means of spill prevention, control, or countermeasure. Where your Plan does not conform to the applicable requirements in paragraphs (g), (h)(2) and (3), and (i) of this section, or the requirements of subparts B and C of this part, except the secondary containment requirements in paragraph (c) and (h)(1) of this section, and [§§112.8\(c\)\(2\)](#), [112.8\(c\)\(11\)](#), [112.9\(c\)\(2\)](#), [112.10\(c\)](#), [112.12\(c\)\(2\)](#), and [112.12\(c\)\(11\)](#), you must state the reasons for nonconformance in your Plan and describe in detail alternate methods and how you will achieve equivalent environmental protection. If the Regional Administrator determines that the measures described in your Plan do not provide equivalent environmental protection, he may require that you amend your Plan, following the procedures in [§112.4\(d\)](#) and [\(e\)](#).

(a)(3) Describe in your Plan the physical layout of the facility and include a facility diagram, which must mark the location and contents of each fixed oil storage container and the storage area where mobile or portable containers are located. The facility diagram must identify the location of and mark as "exempt" underground tanks that are otherwise exempted from the requirements of this part under [§112.1\(d\)\(4\)](#). The facility diagram must also include all transfer stations and connecting pipes, including intra-facility gathering lines that are otherwise exempted from the requirements of this part under [§112.1\(d\)\(11\)](#). You must also address in your Plan:

(a)(3)(i) The type of oil in each fixed container and its storage capacity. For mobile or portable containers, either provide the type of oil and storage capacity for each container or provide an estimate of the potential number of mobile or portable containers, the types of oil, and anticipated storage capacities;

(a)(3)(ii) Discharge prevention measures including procedures for routine handling of products (loading, unloading, and facility transfers, etc.);

(a)(3)(iii) Discharge or drainage controls such as secondary containment around containers and other structures, equipment, and procedures for the control of a discharge;

(a)(3)(iv) Countermeasures for discharge discovery, response, and cleanup (both the facility's capability and those that might be required of a contractor);

(a)(3)(v) Methods of disposal of recovered materials in accordance with applicable legal requirements; and

(a)(3)(vi) Contact list and phone numbers for the facility response coordinator, National Response Center, cleanup contractors with whom you have an agreement for response, and all

appropriate Federal, State, and local agencies who must be contacted in case of a discharge as described in [§112.1\(b\)](#).

(a)(4) Unless you have submitted a response plan under [§112.20](#), provide information and procedures in your Plan to enable a person reporting a discharge as described in [§112.1\(b\)](#) to relate information on the exact address or location and phone number of the facility; the date and time of the discharge, the type of material discharged; estimates of the total quantity discharged; estimates of the quantity discharged as described in [§112.1\(b\)](#); the source of the discharge; a description of all affected media; the cause of the discharge; any damages or injuries caused by the discharge; actions being used to stop, remove, and mitigate the effects of the discharge; whether an evacuation may be needed; and, the names of individuals and/or organizations who have also been contacted.

(a)(5) Unless you have submitted a response plan under [§112.20](#), organize portions of the Plan describing procedures you will use when a discharge occurs in a way that will make them readily usable in an emergency, and include appropriate supporting material as appendices.

(b) Where experience indicates a reasonable potential for equipment failure (such as loading or unloading equipment, tank overflow, rupture, or leakage, or any other equipment known to be a source of a discharge), include in your Plan a prediction of the direction, rate of flow, and total quantity of oil which could be discharged from the facility as a result of each type of major equipment failure.

(c) Provide appropriate containment and/or diversionary structures or equipment to prevent a discharge as described in [§112.1\(b\)](#), except as provided in paragraph (k) of this section for qualified oil-filled operational equipment, and except as provided in [§112.9\(d\)\(3\)](#) for flowlines and intra-facility gathering lines at an oil production facility. The entire containment system, including walls and floor, must be capable of containing oil and must be constructed so that any discharge from a primary containment system, such as a tank, will not escape the containment system before cleanup occurs. In determining the method, design, and capacity for secondary containment, you need only to address the typical failure mode, and the most likely quantity of oil that would be discharged. Secondary containment may be either active or passive in design. At a minimum, you must use one of the following prevention systems or its equivalent:

(c)(1) For onshore facilities:

(c)(1)(i) Dikes, berms, or retaining walls sufficiently impervious to contain oil;

(c)(1)(ii) Curbing or drip pans;

(c)(1)(iii) Sumps and collection systems;

(c)(1)(iv) Culverting, gutters, or other drainage systems;

(c)(1)(v) Weirs, booms, or other barriers;

(c)(1)(vi) Spill diversion ponds;

(c)(1)(vii) Retention ponds; or

(c)(1)(viii) Sorbent materials.

(c)(2) For offshore facilities:

(c)(2)(i) Curbing or drip pans; or

(c)(2)(ii) Sumps and collection systems.

(d) Provided your Plan is certified by a licensed Professional Engineer under [§112.3\(d\)](#), or, in the case of a qualified facility that meets the criteria in [§112.3\(g\)](#), the relevant sections of your Plan are certified by a licensed Professional Engineer under §112.6(d), if you determine that the installation of any of the structures or pieces of equipment listed in paragraphs (c) and (h)(1) of this section, and [§§112.8\(c\)\(2\)](#), [112.8\(c\)\(11\)](#), [112.9\(c\)\(2\)](#), [112.10\(c\)](#), [112.12\(c\)\(2\)](#), and [112.12\(c\)\(11\)](#) to prevent a discharge as described in [§112.1\(b\)](#) from any onshore or offshore facility is not practicable, you must clearly explain in your Plan why such measures are not practicable; for bulk storage containers, conduct both periodic integrity testing of the containers and periodic integrity and leak testing of the valves and piping; and, unless you have submitted a response plan under [§112.20](#), provide in your Plan the following:

(d)(1) An oil spill contingency plan following the provisions of [part 109](#) of this chapter.

(d)(2) A written commitment of manpower, equipment, and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful.

(e) *Inspections, tests, and records.* Conduct inspections and tests required by this part in accordance with written procedures that you or the certifying engineer develop for the facility. You must keep these written procedures and a record of the inspections and tests, signed by the appropriate supervisor or inspector, with the SPCC Plan for a period of three years. Records of inspections and tests kept under usual and customary business practices will suffice for purposes of this paragraph.

(f) *Personnel, training, and discharge prevention procedures.* (1) At a minimum, train your oil-handling personnel in the operation and maintenance of equipment to prevent discharges; discharge procedure protocols; applicable pollution control laws, rules, and regulations; general facility operations; and, the contents of the facility SPCC Plan.

(f)(2) Designate a person at each applicable facility who is accountable for discharge prevention and who reports to facility management.

(f)(3) Schedule and conduct discharge prevention briefings for your oil-handling personnel at least once a year to assure adequate understanding of the SPCC Plan for that facility. Such

briefings must highlight and describe known discharges as described in [§112.1\(b\)](#) or failures, malfunctioning components, and any recently developed precautionary measures.

(g) *Security (excluding oil production facilities)*. Describe in your Plan how you secure and control access to the oil handling, processing and storage areas; secure master flow and drain valves; prevent unauthorized access to starter controls on oil pumps; secure out-of-service and loading/unloading connections of oil pipelines; and address the appropriateness of security lighting to both prevent acts of vandalism and assist in the discovery of oil discharges.

(h) Facility tank car and tank truck loading/unloading rack (excluding offshore facilities).

**(h)(1)** Where loading/unloading rack drainage does not flow into a catchment basin or treatment facility designed to handle discharges, use a quick drainage system for tank car or tank truck loading/unloading racks. You must design any containment system to hold at least the maximum capacity of any single compartment of a tank car or tank truck loaded or unloaded at the facility.

**(h)(2)** Provide an interlocked warning light or physical barrier system, warning signs, wheel chocks or vehicle brake interlock system in the area adjacent to a loading/unloading rack, to prevent vehicles from departing before complete disconnection of flexible or fixed oil transfer lines.

**(h)(3)** Prior to filling and departure of any tank car or tank truck, closely inspect for discharges the lowermost drain and all outlets of such vehicles, and if necessary, ensure that they are tightened, adjusted, or replaced to prevent liquid discharge while in transit.

(i) If a field-constructed aboveground container undergoes a repair, alteration, reconstruction, or a change in service that might affect the risk of a discharge or failure due to brittle fracture or other catastrophe, or has discharged oil or failed due to brittle fracture failure or other catastrophe, evaluate the container for risk of discharge or failure due to brittle fracture or other catastrophe, and as necessary, take appropriate action.

(j) In addition to the minimal prevention standards listed under this section, include in your Plan a complete discussion of conformance with the applicable requirements and other effective discharge prevention and containment procedures listed in this part or any applicable more stringent State rules, regulations, and guidelines.

(k) *Qualified Oil-filled Operational Equipment*. The owner or operator of a facility with oil-filled operational equipment that meets the qualification criteria in paragraph (k)(1) of this sub-section may choose to implement for this qualified oil-filled operational equipment the alternate requirements as described in paragraph (k)(2) of this sub-section in lieu of general secondary containment required in paragraph (c) of this section.

**(k)(1) *Qualification Criteria--Reportable Discharge History***: The owner or operator of a facility that has had no single discharge as described in [§112.1\(b\)](#) from any oil-filled operational equipment exceeding 1,000 U.S. gallons or no two discharges as described in [§112.1\(b\)](#) from any oil-filled operational equipment each exceeding 42 U.S. gallons within any twelve month period

in the three years prior to the SPCC Plan certification date, or since becoming subject to this part if the facility has been in operation for less than three years (other than oil discharges as described in [§112.1\(b\)](#) that are the result of natural disasters, acts of war or terrorism); and

**(k)(2)** *Alternative Requirements to General Secondary Containment.* If secondary containment is not provided for qualified oil-filled operational equipment pursuant to paragraph (c) of this section, the owner or operator of a facility with qualified oil-filled operational equipment must:

**(k)(2)(i)** Establish and document the facility procedures for inspections or a monitoring program to detect equipment failure and/or a discharge; and

**(k)(2)(ii)** Unless you have submitted a response plan under [§112.20](#), provide in your Plan the following:

**(k)(2)(ii)(A)** An oil spill contingency plan following the provisions of [part 109](#) of this chapter.

**(k)(2)(ii)(B)** A written commitment of manpower, equipment, and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful.